

CRRUA Water Public Notice

January 29, 2024. A communication error has occurred in the water system causing a water tank that distributes water to the Sunland Park area to drop to a low level. Some areas in Sunland Park may experience discolored water momentarily until the water tank resumes to normal levels. The water tank communication error has thus been resolved; it is advised for residents to flush their sinks for 10 minutes if experiencing discolored water. The discoloration should not last longer than 24 hours if discoloration occurs call CRRUA Administrative Office 575-589-1075.