Arsenic Water Sample Test Results

*CRRUA excluded the Border Entry ATF from its voluntary twice monthly testing this test period due to its continued meeting of all NMED requirements.

| *CRRUA RESULTS/MAY 21, 2024 | | |
|------------------------------------|--------------|-------------|
| Sample Location | Sample | Arsenic MCL |
| Arsenic Treatment Facility (ATF) | Result (ppb) | 10 (ppb) |
| Sunland Park (ATF) | 7.0 | Below MCL |
| Santa Teresa Community (ATF) | 4.1 | Below MCL |
| Santa Teresa Industrial Park (ATF) | 4.5 | Below MCL |
| Border Entry (ATF) | Excluded | N/A |

| *CRRUA RESULTS/MAY 7, 2024 | | |
|------------------------------------|--------------|-------------|
| Sample Location | Sample | Arsenic MCL |
| Arsenic Treatment Facility (ATF) | Result (ppb) | 10 (ppb) |
| Sunland Park (ATF) | 5.0 | Below MCL |
| Santa Teresa Community (ATF) | 2.8 | Below MCL |
| Santa Teresa Industrial Park (ATF) | 4.1 | Below MCL |
| Border Entry (ATF) | Excluded | N/A |

| *CRRUA RESULTS/APRIL 16, 2024 | | |
|------------------------------------|---------------|-------------|
| Sample Location | Sample Result | Arsenic MCL |
| Arsenic Treatment Facility (ATF) | (ppb) | 10 (ppb) |
| Sunland Park (ATF) | 3.0 | Below MCL |
| Santa Teresa Community (ATF) | 4.5 | Below MCL |
| Santa Teresa Industrial Park (ATF) | 3.0 | Below MCL |
| Border Entry (ATF) | Excluded | N/A |

| NMED RESULTS/APRIL 3, 2024 2 nd QUUARTER TEST | | |
|---|---------------------|----------------------------|
| Sample Location Arsenic Treatment Facility (ATF) | Sample Result (ppb) | Arsenic MCL 10 (ppb) |
| Storage Tank #1 (Border Entry) | 3.0 | Below MCL |
| Industrial Park Arsenic (ATF) | 7.0 | Below MCL |
| Sunland Park Arsenic (ATF) | 5.0 | Below MCL |
| Santa Teresa Community | 6.0 | Below MCL |

| CRRUA RESULTS/APRIL 2, 2024 | NMED Certified Lab | |
|--|-----------------------|----------------------------|
| Sample Location Arsenic Treatment Facility (ATF) | Sample Result (ppb) | Arsenic MCL 10 (ppb) |
| Loves Truck Stop Hose Bib #5 | 7.9 | Below MCL |
| Santa Teresa Community (ATF) | 4.6 | Below MCL |
| Santa Teresa Industrial Park (ATF) | 7.4 | Below MCL |
| Sunland Park | 4.4 | Below MCL |

| CRRUA RESULTS/MARCH 18, 2024 | NMED Certified Lab | |
|--|-----------------------|----------------------------|
| Sample Location Arsenic Treatment Facility (ATF) | Sample Result (ppb) | Arsenic MCL 10 (ppb) |
| Sunland Park (ATF) | No Detection | Below MCL |
| Santa Teresa Community (ATF) | 9.7 | Below MCL |
| Santa Teresa Industrial Park (ATF) | 6.6 | Below MCL |
| Border Entry (ATF) | No Detection | Below MCL |

| CRRUA RESULTS/MARCH 6, 2024 | NMED Certified Lab | |
|--|-----------------------|----------------------------|
| Sample Location Arsenic Treatment Facility (ATF) | Sample Result (ppb) | Arsenic MCL 10 (ppb) |
| Sunland Park (ATF) | 6.8 | Below MCL |
| Santa Teresa Community (ATF) | 7.3 | Below MCL |
| Santa Teresa Industrial Park (ATF) | 9.4 | Below MCL |
| Border Entry (ATF) | 2.9 | Below MCL |