

## Arsenic Water Sample Test Results

CRRUA operates four arsenic treatment facilities and in January 2024 initiated voluntary twice monthly testing at all four facilities.

In May 2024, \*CRRUA excluded the Border Entry facility from its voluntary twice monthly testing due to its continued meeting of all NMED requirements. (CRRUA included the Border Entry facility in the second of two July 2024 arsenic tests.)

In June 2024, CRRUA went from twice monthly to monthly voluntary testing due to its continued meeting of all NMED requirements. NMED conducts quarterly testing. (CRRUA conducted two voluntary arsenic tests in July 2024.)

A video on the arsenic removal process is available on the CRRUA YouTube channel at [www.youtube.com/@crrua\\_info](http://www.youtube.com/@crrua_info).

<b>NMED RESULTS/July 30, 2024 3<sup>rd</sup> QUARTER TEST</b>		
<b>Sample Location</b>	<b>Sample Result (ppb)</b>	<b>Arsenic MCL 10 (ppb)</b>
Arsenic Treatment Facility (ATF)	3.0	Below MCL
Santa Teresa Border Entry (ATF)	4.0	Below MCL
Industrial Park Arsenic (ATF)	9.0	Below MCL
*Sunland Park Arsenic (ATF)	5.0	Below MCL
Santa Teresa Community		

<b>CRRUA RESULTS/AUG. 21, 2024</b>		
<b>Sample Location</b>	<b>Sample Result (ppb)</b>	<b>Arsenic MCL 10 (ppb)</b>
Arsenic Treatment Facility (ATF)	9.5	Below MCL
Sunland Park (ATF)	5.8	Below MCL
Santa Teresa Community (ATF)	7.8	Below MCL
Santa Teresa Industrial Park (ATF)	Excluded	N/A
Border Entry (ATF)		

<b>CRRUA RESULTS/JULY 31, 2024</b>		
<b>Sample Location</b>	<b>Sample Result (ppb)</b>	<b>Arsenic MCL 10 (ppb)</b>
Arsenic Treatment Facility (ATF)	8.8	Below MCL
Sunland Park (ATF)	5.6	Below MCL
Santa Teresa Community (ATF)	3.8	Below MCL
Santa Teresa Industrial Park (ATF)	3.2	Below MCL
Border Entry (ATF)		

<b>*CRRUA RESULTS/JULY 2, 2024</b>		
<b>Sample Location</b>	<b>Sample Result (ppb)</b>	<b>Arsenic MCL 10 (ppb)</b>
Arsenic Treatment Facility (ATF)	7.2	Below MCL
Sunland Park (ATF)	4.9	Below MCL
Santa Teresa Community (ATF)	7.3	Below MCL
Santa Teresa Industrial Park (ATF)	Excluded	N/A
Border Entry (ATF)		

<b>*CRRUA RESULTS/JUNE 11, 2024</b>		
<b>Sample Location</b>	<b>Sample Result (ppb)</b>	<b>Arsenic MCL 10 (ppb)</b>
Arsenic Treatment Facility (ATF)	8.2	Below MCL
Sunland Park (ATF)	7.2	Below MCL
Santa Teresa Community (ATF)	13.0	Above MCL
Santa Teresa Industrial Park (ATF)	Excluded	N/A
Border Entry (ATF)		

<b>*CRRUA RESULTS/MAY 21, 2024</b>		
<b>Sample Location</b>	<b>Sample Result (ppb)</b>	<b>Arsenic MCL 10 (ppb)</b>
Arsenic Treatment Facility (ATF)	7.0	Below MCL
Sunland Park (ATF)	4.1	Below MCL
Santa Teresa Community (ATF)	4.5	Below MCL
Santa Teresa Industrial Park (ATF)	Excluded	N/A
Border Entry (ATF)		

<b>*CRRUA RESULTS/MAY 7, 2024</b>		
<b>Sample Location</b>	<b>Sample Result (ppb)</b>	<b>Arsenic MCL 10 (ppb)</b>
Arsenic Treatment Facility (ATF)	5.0	Below MCL
Sunland Park (ATF)	2.8	Below MCL
Santa Teresa Community (ATF)	4.1	Below MCL
Santa Teresa Industrial Park (ATF)	Excluded	N/A
Border Entry (ATF)		

<b>*CRRUA RESULTS/APRIL 16, 2024</b>		
<b>Sample Location</b>	<b>Sample Result (ppb)</b>	<b>Arsenic MCL 10 (ppb)</b>
Arsenic Treatment Facility (ATF)	3.0	Below MCL
Sunland Park (ATF)	4.5	Below MCL
Santa Teresa Community (ATF)	3.0	Below MCL
Santa Teresa Industrial Park (ATF)	Excluded	N/A
Border Entry (ATF)		

<b>NMED RESULTS/APRIL 3, 2024 2<sup>nd</sup> QUARTER TEST</b>		
<b>Sample Location</b>	<b>Sample Result (ppb)</b>	<b>Arsenic MCL 10 (ppb)</b>
Arsenic Treatment Facility (ATF)	3.0	Below MCL
Storage Tank #1 (Border Entry)	7.0	Below MCL
Industrial Park Arsenic (ATF)	5.0	Below MCL
Sunland Park Arsenic (ATF)	6.0	Below MCL
Santa Teresa Community		

<b>CRRUA RESULTS/APRIL 2, 2024</b>		
	<b>NMED Certified Lab</b>	
<b>Sample Location</b>	<b>Sample Result (ppb)</b>	<b>Arsenic MCL 10 (ppb)</b>
Arsenic Treatment Facility (ATF)		
Loves Truck Stop Hose Bib #5	7.9	Below MCL
Santa Teresa Community (ATF)	4.6	Below MCL
Santa Teresa Industrial Park (ATF)	7.4	Below MCL
Sunland Park	4.4	Below MCL

<b>CRRUA RESULTS/MARCH 18, 2024</b>		
	<b>NMED Certified Lab</b>	
<b>Sample Location</b>	<b>Sample Result (ppb)</b>	<b>Arsenic MCL 10 (ppb)</b>
Arsenic Treatment Facility (ATF)		
Sunland Park (ATF)	No Detection	Below MCL
Santa Teresa Community (ATF)	9.7	Below MCL
Santa Teresa Industrial Park (ATF)	6.6	Below MCL
Border Entry (ATF)	No Detection	Below MCL

<b>CRRUA RESULTS/MARCH 6, 2024</b>		
	<b>NMED Certified Lab</b>	
<b>Sample Location</b>	<b>Sample Result (ppb)</b>	<b>Arsenic MCL 10 (ppb)</b>
Arsenic Treatment Facility (ATF)		
Sunland Park (ATF)	6.8	Below MCL
Santa Teresa Community (ATF)	7.3	Below MCL
Santa Teresa Industrial Park (ATF)	9.4	Below MCL
Border Entry (ATF)	2.9	Below MCL

<b>CRRUA RESULTS/February 7, 2024</b>		
	<b>NMED Certified Lab</b>	
<b>Sample Location</b>	<b>Sample Result (ppb)</b>	<b>Arsenic MCL 10 (ppb)</b>
Arsenic Treatment Facility (ATF)		
Sunland Park (ATF)	3.0	Below MCL
Santa Teresa Community (ATF)	9.8	Below MCL
Santa Teresa Industrial Park (ATF)	1.7	Below MCL
Border Entry (ATF)	3.3	Below MCL

<b>CRRUA RESULTS/JANUARY 24, 2024</b>		
	<b>NMED Certified Lab</b>	
<b>Sample Location</b>	<b>Sample Result (ppb)</b>	<b>Arsenic MCL 10 (ppb)</b>
Arsenic Treatment Facility (ATF)		
Sunland Park (ATF)	9.6	Below MCL
Santa Teresa Industrial (ATF)	8.4	Below MCL
Santa Teresa Community (ATF)	3.5	Below MCL
Border Entry (ATF)	3.0	Below MCL